

SWBNO 8-27-2021

Ghassan Korban, gkorban@swbno.org, 504-439-3232

■ Drainage and Power Equipment Status – 8-27-21

- 96 of 99 drainage major pumps currently available for service.
 - **DPS #6 - I Pump**
 - **DPS #12 – D Pump**
 - **DPS #14 – No. 4 Pump**

■ Power Status

- Turbine 1 Out of Service
- Turbine 4 (18 MW) Out of Service (Operations will be working through this weekend to start testing the machine on Saturday)
- Turbines 5 (17.5 MW) available (25 Hz)
- Turbine 6 (15 MW) available (60 Hz)
- Frequency Changers available (utilizing ENO or T6) (22 MW Total)
- Electro-Motive Diesel (EMD) 2,3,4, and 5 generators (25 Hz) (10 MW Total)
- EMD #1(2.5 MW) is offline undergoing control and fan upgrades
- General Superintendent held Storm Preparation Meeting with Staff on 8-27-21
- SWBNO EOC Managers meeting to be held at 12 noon

