



# **The Sewerage & Water Board**

## **OF NEW ORLEANS**

625 ST. JOSEPH STREET  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

**June 20, 2024**

Dear Mayor Cantrell, Honorable Members of the New Orleans City Council, and Orleans Parish Legislative Delegation:

This report is delivered in accordance which Revised Statute 33:4091, Section F, which states: *“In addition to the other requirements of this Section, the board shall send a report, by electronic mail, to the members of the Orleans Parish legislative delegation and the members of the governing authority of Orleans Parish detailing the pumping and electrical power of its facilities and the available manpower no later than twenty-four hours prior to a hurricane entering the Gulf of Mexico as determined by the National Weather Service and no later than forty-eight hours after a flood watch or warning or thunderstorm watch or warning is issued by the National Weather Service for any area of Orleans Parish.”*

Beginning in the morning hours of June 17, 2024, a line of thunderstorms impacted the New Orleans area. The initial predictions from the National Weather Service called for likely showers and thunderstorms, with rainfall accumulation between 1-2” possible. The status of SWBNO’s pumping and power equipment before and during the events is detailed below.

### **STORM IMPACTS**

The storm began just before 9 AM and continued to impact the area throughout the day; the majority of rainfall accumulation was between 9am and 5pm. The highest recorded accumulation was 2.8 inches at DPS 14 in New Orleans East. The average accumulation across stations monitored was 1.3 inches. The highest rainfall intensity was observed at DPS 2 at 5.16 inches/hour. The average rainfall intensity across the states monitored was 2.37 inches/hour. Accumulation of over 1-inch per hour was observed at multiple stations in the Uptown, Lakeview, and Mid City areas, as well

as in New Orleans East. Note that data was not available from DPS 3, 15, 17, and 19.

There were no reports of localized pooling or flooding from the Real Time Crime Center for this rain event.

## **PUMPING AND POWER**

Below is the status of SWBNO's pumping and power equipment at the outset of the event.

### **Drainage Pumps:**

A total of 90 of 99 drainage pumps were reported in service at the outset of the event.

- DPS 6:** 1 pump is out of service while inspection of pump is in progress to determine the extent of any repairs needed. RTS TBD.
- DPS 10:** No. 1 pump (60-hz) out of service. Vendor selected to refurbish pump. RTS August 2024.
- DPS 13:** No. 4 pump (diesel pump) is for emergency use only. Additional drainage funding is needed to move forward with repairs.
- DPS 14:** No. 3 and No. 4 pumps out of service due to mechanical issues. RTS pending contractor work required.  
*Note that drainage from this area can also be addressed by DPS 10, DPS 16, and Dwyer DPS via the Morrison Canal.*
- DPS 15:** No. 1 pump gearbox repairs are in progress. RTS Q2 2025.
- DPS 17:** Pumps A & D (25-hz) out of service due to the issues with electric motor. RTS TBD, pending funding availability.
- DPS 18:** Pump No. 1 out of service as of May 2024. RTS pending further mechanical inspection.  
*A portable pump was installed at this location as a temporary measure.*

No pump-related issues were encountered during these events.

### **Underpass Stations:**

All 27 underpass station pumps (UPS) were available and ready for use during the event, with no issues reported.

### **Power:**

Turbines 5 (25-hz), and 6 (60-hz), along with four frequency changers on the Eastbank, and one on the Westbank, as well as three EMDs were also available at the outset of this event.

Due to the limited amount of redundancy in 25-hz power, plans were made in advance of the rain event to utilize frequency changers for the stations which serve primarily 25-hz pumps.

A combination of Frequency Changers and T5 were used for these rain events, with no major issues encountered.

<b>Unit*</b>	<b>Frequency</b>	<b>Capacity in MW</b>	<b>Available</b>
T4	25 Hz	20 MW	0 (placed out of service on February 3, 2024)
T5**	25 Hz	20 MW	16 MW (revised capacity while Turbine 4 is out of service)
Carrollton Frequency Changers 1&2	Converts 60 to 25Hz	8.5 MW	8.5
Station D Frequency Changers 3&4	Converts 60 to 25Hz	12 MW	12 MW
West Bank Power Complex (Algiers Water Treatment Plant)	Converts 60 to 25Hz	2.5 MW	2.5
Five EMDs	25Hz	12.5 MW (total) 2.5 MW (each)	7.5 (repairs for EMD #1 in progress; #2 EMD out of service for oil leak on 6/15, returned to service by end of day 6/17)
Plant Frequency Changer via T6	Converts 60 to 25Hz	3.75 MW	0 MW (RTS to be determined)
		<b>Total 25 Hz:</b>	<b>46.5 MW</b>
T6	60 Hz	22 MW	<b>22 MW</b>

\*T3 has been decommissioned as of May 2021, and T1 has been decommissioned as of June 2022. Both units have been removed from this table.

## **STAFFING**

Of New Orleans' 24 drainage pumping stations, some are staffed, some run remotely, and some are staffed as circumstances dictate. For this event, all stations were staffed appropriately.