



# **The Sewerage & Water Board**

## **OF NEW ORLEANS**

625 ST. JOSEPH STREET  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

**March 26, 2025**

Dear Mayor Cantrell, Honorable Members of the New Orleans City Council, and Orleans Parish Delegation:

This report is delivered in accordance with Revised Statute 33:4091, Section F, which states: *“In addition to the other requirements of this Section, the board shall send a report, by electronic mail, to the members of the Orleans Parish legislative delegation and the members of the governing authority of Orleans Parish detailing the pumping and electrical power of its facilities and the available manpower no later than twenty-four hours prior to a hurricane entering the Gulf of Mexico as determined by the National Weather Service and no later than forty eight hours after a flood watch or warning or thunderstorm watch or warning is issued by the National Weather Service for any area of Orleans Parish.”*

A Flash Flood and Severe Thunderstorm warning were issued for Orleans Parish on the evening March 15, 2025 due to a series of rainstorms that moved through the area that evening. The status of SWBNO’s pumping and power equipment before and during the events is detailed below.

### **STORM IMPACTS**

This high intensity, short-duration rain event entered the New Orleans area around 5pm on March 15, 2025 and ended around 7pm that day. The average recorded rainfall was 0.34 inches, with the highest recorded rainfall amount of 0.68 inches at DPS 12 in Lakeview. The average rain rate was 2.16 inches per hour, with the highest recorded rainfall rate of 5.28 inches per hour observed at DPS 12 in Lakeview. Rainfall rates exceeding 2 inches/hour were recorded at multiple locations across the City.

No reports of flooding or concern were noted by the Real Time Crime Center (RTCC).

## **PUMPING AND POWER**

Below is the status of SWBNO's pumping and power equipment at the outset of the event.

### **Drainage Pumps:**

A total of 89 of 93 drainage pumps were reported in service at the outset of the event. No issues with the pumps at the drainage stations were encountered during this event.

- DPS 13:**      **No. 4 pump (diesel pump) is for emergency use only. Additional drainage funding is needed to move forward with repairs.**  
*5 additional pumps were available at this station*
- DPS 14:**      **No. 3 pump out of service due to mechanical issues. #3 repairs will be completed via contract, with RTS anticipated in Q1 2025.**  
*3 additional pumps were available at this station*  
*Note that drainage from this area can also be addressed by DPS 10, DPS 16, and Dwyer DPS via the Morrison Canal.*
- DPS 15:**      **No. 1 pump gearbox repairs are in progress. RTS Q2 2025.**  
*2 additional pumps were available at this station*
- DPS 18:**      **Pump No. 1 out of service as of May 2024. RTS pending further mechanical inspection and repairs.**  
*1 additional pump is available at this station, and a portable pump was installed at this location as a temporary measure.*

### **Underpass Stations:**

At UPS Old Carrollton, which services the Carrollton Ave/Interstate I-10 underpass, two of three pumps at that location are out of service. Prior to this event, only one of the three pumps was out of service. A temporary pump is also deployed at this location.

No issues reported with the remaining underpass pumps or stations during these rain events.

**Power:**

Prior to the event, 70 MW of 25-hz power was available via Turbines 4 and 5, four frequency changers on the Eastbank, one frequency changer on the Westbank, and five EMDs. Turbine 6 was also available.

A combination of Frequency Changers and Turbine 5 were used for this event, with no major issues encountered.

<b>Unit*</b>	<b>Frequency</b>	<b>Capacity in MW</b>	<b>Available</b>
T4	25 Hz	20 MW (18.5 MW revised capacity)	18.5 MW
T5	25 Hz	20 MW (16 MW revised capacity)	16 (revised capacity)
Carrollton Frequency Changers 1&2	Converts 60 to 25Hz	8.5 MW	8.5
Station D Frequency Changers 3&4	Converts 60 to 25Hz	12 MW	12
West Bank Power Complex (Algiers Water Treatment Plant)	Converts 60 to 25Hz	2.5 MW	2.5
Five EMDs	25Hz	12.5 MW (total) 2.5 MW (each)	12.5
Plant Frequency Changer via T6	Converts 60 to 25Hz	3.75 MW	0 MW (RTS to be determined)
		<b>Total 25 Hz:</b>	<b>70 MW</b>
T6	60 Hz	22 MW	<b>22 MW</b>

\*T3 has been decommissioned as of May 2021, and T1 has been decommissioned as of June 2022. Both units have been removed from this table.

**STAFFING**

Of New Orleans' 24 drainage pumping stations, some are staffed, some run remotely, and some are staffed as circumstances dictate. For this event, all stations were staffed appropriately.