



# **The Sewerage & Water Board**

## **OF NEW ORLEANS**

625 ST. JOSEPH STREET  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

**August 1, 2025**

Dear Mayor Cantrell, Honorable Members of the New Orleans City Council, and Orleans Parish Delegation:

This report is delivered in accordance with Revised Statute 33:4091, Section F, which states: *“In addition to the other requirements of this Section, the board shall send a report, by electronic mail, to the members of the Orleans Parish legislative delegation and the members of the governing authority of Orleans Parish detailing the pumping and electrical power of its facilities and the available manpower no later than twenty-four hours prior to a hurricane entering the Gulf of Mexico as determined by the National Weather Service and no later than forty eight hours after a flood watch or warning or thunderstorm watch or warning is issued by the National Weather Service for any area of Orleans Parish.”*

A flash flood warning for the New Orleans area was issued for July 30, 2025 due to a series of strong thunderstorms moving through the area. The status of SWBNO's pumping and power equipment before and during the events is detailed below.

### **STORM IMPACTS**

The afternoon thunderstorms lasted between just before 2:00 PM until just before 5:00 PM. The highest recorded collection amount was from DPS-13 in Algiers at 1.9 inches. The average collection amount across the network was 0.4 inches. The highest rain rate per hour was also observed at DPS-13 in Algiers at 3.8 inches per hour. The average rain rate across the network was 1.1 inches per hour.

The RTCC did not report any flooding.

## **PUMPING AND POWER**

Below is the status of SWBNO's pumping and power equipment at the outset of the event.

### **Drainage Pumps:**

A total of 86 of 93 drainage pumps were reported in service at the outset of the event.

**DPS 4:** E pump is out of service as of June 2025. A contractor has been engaged to repair the pump, with RTS anticipated by the end of August/early September.

*4 additional pumps are available at this station*

**DPS 13:** No. 4 pump (diesel pump) is for emergency use only. Additional drainage funding is needed to move forward with repairs.

No. 6 pump is on standby for emergency use only as of July 2025. An investigation of the repairs needed is underway.

*4 additional pumps are available at this station*

**DPS 14:** No. 3 pump out of service due to mechanical issues. Contractor repair work is underway, with RTS anticipated in Q3 2025.

*3 additional pumps are available at this station*

*Note that drainage from this area can also be addressed by DPS 10, DPS 16, and Dwyer DPS via the Morrison Canal.*

**DPS 15:** No. 1 pump gearbox repairs are in progress. RTS Q3 2025.

*2 additional pumps are available at this station*

**DPS 16:** Pump No. 4 out of service as of June 2025. Repairs to this pump are in progress, with repairs anticipated by end of August 2025.

*3 additional pumps are available at this station*

**DPS 18:** Pump No. 1 out of service as of May 2024. A contractor has been engaged to make the repair, with RTS anticipated by end of Q3 2025.

*1 additional pump is available at this station.*

No pump issues were encountered during the event.

For reference, maps showing the tributaries (i.e. drainage areas) for each pumping station are included on the Pumping and Power Dashboard

(<https://www.swbno.org/Projects/PumpingandPower>), which are included as reference maps at the end of this report.

**Underpass Stations:**

At UPS Old Carrollton, which services the Carrollton Ave/Interstate I-10 underpass, two of three pumps at that location are out of service. A temporary pump is installed at this location.

No issues with the underpass stations were reported during this event.

**Power:**

A combination of Frequency Changers and Turbine 5 were used for this event, with no major pumping or power issues encountered during the event.

<b>Unit*</b>	<b>Frequency</b>	<b>Capacity in MW</b>	<b>Available</b>
T4	25 Hz	20 MW (18.5 MW revised capacity)	18.5
T5	25 Hz	20 MW (16 MW revised capacity)	16
Carrollton Frequency Changers 1&2	Converts 60 to 25Hz	8.5 MW	8.5
Station D Frequency Changers 3&4	Converts 60 to 25Hz	12 MW	12
West Bank Power Complex (Algiers Water Treatment Plant)	Converts 60 to 25Hz	2.5 MW	0 (out of service)
Five EMDs	25Hz	12.5 MW (total) 2.5 MW (each)	12.5
Plant Frequency Changer via T6	Converts 60 to 25Hz	3.75 MW	0 MW (RTS to be determined)
		Total 25 Hz:	<b>67.5 MW</b>
T6	60 Hz	22 MW	

\*T3 has been decommissioned as of May 2021, and T1 has been decommissioned as of June 2022. Both units have been removed from this table.

## STAFFING

Of New Orleans' 24 drainage pumping stations, some are staffed, some run remotely, and some are staffed as circumstances dictate. For this event, all stations were staffed appropriately.

## DRAINAGE AREA REFERENCE MAPS

For a complete map, visit <https://www.swbno.org/Projects/PumpingandPower>







